



Addendum No. 1

**City of Coquitlam
Tender 85261**

**Broadview Court CIPP Repairs
(Consists of 2 Pages)**

Issue Date: July 17, 2024

Tenderers shall note the following changes:

REVISIONS:

1. **Refer to:** AGREEMENT and FORM OF TENDER

DELETE: *Substantial Performance* of the *Work* on or before **December 31, 2024**

REPLACE with: *Substantial Performance* of the *Work* on or before **March 31, 2025**

Substantial Performance Extension to March 31, 2025.

2. **Refer to:** SUPPLEMENTARY CONTRACT SPECIFICATIONS
Section 00 72 43S – Contract Specific Notations

Add to: Clause 3.02 - Contract Schedule, Contract Duration and Charges

Note: Relining of both the sanitary and storm main on Broadview Court must be completed by December 31, 2024.

3. **Refer to:** SUPPLEMENTARY CONTRACT SPECIFICATIONS
Section 33 05 24S – Cured In Place Pipe Liners

Add to: Clause 2.2 – Resin

The following resins are permitted under the terms of this Contract:

- .1 Premium polyester resins that do not contain a styrene monomer;
- .2 Vinyl Ester resins that do not contain a styrene monomer;
- .3 Epoxy resin;
- .4 Premium polyester resins containing styrene when cured only through the Ultra Violet (UV) process.

Contractor Questions/Clarifications

Q1) Can CCTV files be provided?

A1) CCTV files for each pipe have been provided via the following Q File links (please note that files can only be accessed for 30 days). CCTV video can be provided to the successful Contractor upon request.

Link 1 - <https://qfile.coquitlam.ca/files/7aeb2978-ad4b-467f-a49f-aaded653929e>

Link 2 - <https://qfile.coquitlam.ca/files/c2f560a3-51fc-4849-9f15-e0f7ac5e4d58>

Link 3 - <https://qfile.coquitlam.ca/files/1f4df6d3-812f-4ca5-a99f-9c2baa91a68f>

Link 4 - <https://qfile.coquitlam.ca/files/4661196e-069f-4780-9a00-7c7d6a8b8d81>

Link 5 - <https://qfile.coquitlam.ca/files/eda3e6d4-6c46-4f98-a9b4-8a33fae5e5b6>

End of Addendum No. 1

Tenderers shall take into account the content of this Addendum in the preparation and submission of the Tender which will form part of the contract and shall be acknowledged on the Tender Form, Item 1.

Upon submitting a Tender, Tenderers will be deemed to have received notice of all Addenda that are posted on the City's website and deemed to have considered the information for inclusion in the Tender submitted.

Issued by:

Mark Pain

Procurement Manager

Email: bid@coquitlam.ca