

**Addendum No. 2**

**City of Coquitlam
Tender 85262
Saddle Street Sanitary Upgrades
Issue Date: July 23, 2024
(Consists of 1 Page)**

Contractor Questions/Clarifications

Q1) Can CCTV files be provided?

A1) CCTV files have been provided via the following Q File links (please note that files can only be accessed for 30 days). CCTV video can be provided to the successful Contractor upon request.

<https://qfile.coquitlam.ca/files/5ea6c9a6-099b-49aa-a105-7648faed6f00>

Q2) Could you please clarify who will be responsible for the ESC Supervisor mentioned in the supplementary contract specification section 01 57 01S (SS8)? Will it be the City's responsibility or the Contractor's?

A2) The ESC Supervisor is the responsibility of the Contractor.

Q3) Do new services need to be installed at 2% from the property line to the existing main or at 2% from the existing sanitary main to the property line?

A3) All new services will be installed at 2% from the existing sanitary main. Refer to COQ-S7A in Appendix B.

End of Addendum No. 2

Tenderers shall take into account the content of this Addendum in the preparation and submission of the Tender which will form part of the contract and should be acknowledged on the Tender form where indicated.

Upon submitting a Tender, Tenderers will be deemed to have received all addenda and considered the information for inclusion in the Tender submitted.

Issued by:

M. Pain
Procurement Manager
Email: bid@coquitlam.ca