



Addendum No. 1
City of Coquitlam
Tender No. 89033
Greene Street Watermain Replacement
(Consists of 1 Page)

Issue Date: January 28, 2025

Tenderers shall note the following changes:

QUESTIONS AND CLARIFICATIONS:

- Q1.) As the notes on the drawings indicate 75mm temporary asphalt patching, where is the location of surface milling and overlay asphalt on the project?
- A1.) A 35mm surface mill and overlay of the temporary asphalt trench patch will be completed and keyed into the existing asphalt, as per COQ-G4.**
- Q2.) How are property restorations paid for landscape, asphalt curbs and driveways?
- A2.) Payment for property restorations including landscaping, asphalt curbs, and asphalt driveways is incidental to work in other pay items. Please refer to the Supplementary Contract Specifications, Section 33 11 01S, Clause 1.8.2 for details.**
- Q3.) Which asphalt mix should be used for the 75mm temporary asphalt patch?
- A3.) The 75mm temporary asphalt patch mix shall be MMCD Lower Course #1.**

End of Addendum No. 1

Tenderers shall take into account the content of this Addendum in the preparation and submission of the Tender which will form part of the contract and shall be acknowledged on the Tender Form, Item 1.

Upon submitting a Tender, Tenderers will be deemed to have received notice of all Addenda that are posted on the City's website and deemed to have considered the information for inclusion in the Tender submitted.

Issued by:

Mark Pain
Manager Procurement
Email: bid@coquitlam.ca