



Addendum No. 1

City of Coquitlam

RFP No. 25-013

Hazardous Gas Detection Equipment Services

Issue Date: February 25, 2025

Total Page Count: 1

Proponents shall note the following amendments to the RFP documents:

QUESTIONS AND CLARIFICATIONS

Q1. On 5.a), there are fields for CO w/ combo, C₃H₈ w/ combo, and NO₂ w/ combo. Is this intended to refer to the individual sensors in a CO/NO₂, CO/C₃H₈, or other similar multi-sensor detector?

A1. Yes, this refers to the individual sensors.

End of Addendum No. 1

Proponents take into account the content of this Addendum in the preparation and submission of the Proposal which will form part of the Contract and should be acknowledged on the Proposal Submission Form.

Upon submitting a Proposal, Proponents are deemed to have received all addenda that are issued and posted on the City's website and considered the information for inclusion in the Proposal Submission.

Issued by:

Mark Pain

Manager Procurement

bid@coquitlam.ca