



Addendum No. 1
City of Coquitlam
Tender No. 87432
Laurentian Watermain Upgrades
 (Consists of 3 Pages)

Issue Date: December 19, 2025

Tenderers shall note the following changes:

Revisions

1. Refer to: FORM OF TENDER

REMOVE: Appendix 1
REPLACE with: *Revised – Appendix 1 – Revision No. 1*

Questions & Clarifications

- Q1) The schedule of quantities items 11.01 to 11.05 are Watermain DI PC350? Coquitlam Supplementary indicate Class 50 & Drawing Notes CLASS 50 TR FLEX? What spec are we going with?
- A1) **Proposed watermain to be installed are DI CL50 TR FLEX (V-bio encased). Refer to FORM OF TENDER: *Revised – Appendix 1 – Revision No. 1*, Pay Items 11.01 to 11.05.**

End of Addendum No. 1

Tenderers shall take into account the content of this Addendum in the preparation and submission of the Tender which will form part of the contract and should be acknowledged on the Tender form where indicated.

Upon submitting a Tender, Tenderers will be deemed to have received all addenda and considered the information for inclusion in the Tender submitted.

Issued by:

M. Pain
 Manager Procurement
 Email: bid@coquitlam.ca

Revised - APPENDIX 1 - Revision No. 1

FORM OF TENDER

Contract 87432

Laurentian Cres Watermain Upgrades

SCHEDULE OF QUANTITIES AND PRICES

(see paragraph 5.3.1 of the Instruction to Tenderers)

(All Tender and Contract Prices shall NOT include GST. GST will apply upon payment)

(Should there be any discrepancy in the information provided, the City's original file copy shall prevail)

ITEM NO.	MMCD Ref. / (Supp. Specs)	DESCRIPTION	UNIT	QTY	UNIT PRICE	EXTENDED AMOUNT
1.00	01 55 00S	TRAFFIC CONTROL, VEHICLE ACCESS AND PARKING				
1.01	(1.5.1)	Traffic Control and Management	Incidental to Contract			
2.00	01 57 01S	ENVIRONMENTAL PROTECTION				
2.01	(1.6.1)	ESC supply & installation, maintenance and removal	Incidental to Contract			
3.00	01 58 01S	PROJECT IDENTIFICATION				
3.01	(1.3.1)	Construction Zone Information Signs	ea.	6		
3.02	(1.3.2)	Changeable Message Sign Board (CMS) (x2 signs - to be used when work is scheduled on Austin Ave only)	month	1		
4.00	03 30 20S	CONCRETE WALKS, CURBS, AND GUTTERS				
4.01	(1.4.3)	Barrier Curb and Gutter Restoration as per Standard Detail COQ-C6	l.m.	80		
4.02	(1.4.5)	Monolithic sidewalk restoration as per Standard Detail COQ-C8	sq.m	8		
4.03	(1.4.5)	Monolithic driveway restoration as per Standard Detail COQ-C7C (Provisional)	sq.m	15		
4.04	(1.4.5)	Concrete Sidewalk, Walkway Connector, Pedestrian Letdown Restoration - 100mm Thick - Broom Finished	sq.m	46		
4.05	(1.4.5)	Concrete Driveway Letdown Restoration - 190mm Thick - as per Standard Detail COQ-C7	sq.m	15		
4.06	(1.4.5)	Concrete Panel Driveway Restoration - 190mm Thick - c/w Turf Strips at 526 Laurentian Cres	sq.m	5		
4.07	(1.4.10)	Tactile Strip - 24x48in. - Access Tile, Yellow color - Removable Type (Provisional)	ea.	1		
5.00	03 40 01S	PRECAST CONCRETE				
5.01	(1.4.2)	Supply and Install Allan Block Wall at 502 Laurentian Driveway c/w re-using and re-instating surface-mounted handrails	sq.m	2		
6.00	31 11 41S	SHRUB AND TREE PRESERVATION				
6.01	(1.3.2)	Hydro Excavation	Allowance			\$5,000.00
7.00	31 23 01S	EXCAVATING, TRENCHING AND BACKFILLING				
7.01	(1.10.3)	Overexcavation w/ Granular Base Backfill (Provisional)	cu.m	50		
8.00	32 01 16.7S	COLD MILLING				
8.01	(1.5.1)	Surface Mill - 50mm depth on Laurentian Cres (Provisional)	sq.m	1,300		
8.02	(1.5.1)	Surface Mill - 70mm on Austin Ave (Provisional)	sq.m	50		
9.00	32 12 13.1S	ASPHALT TACK COAT				
9.01	(1.5.1)	Asphalt Tack Coat	sq.m	1,350		
10.00	32 12 16S	HOT-MIX ASPHALT CONCRETE PAVING				
10.01	(1.5.1)	Hot-Mix Asphalt - 50mm Overlay on Laurentian Cres & 70mm Overlay on Austin Ave - MMCD Upper Course #1	tonne	175		
11.00	33 11 01S	WATERWORKS				
11.01	(1.8.2)	Watermain DI CL50 TR FLEX (V-Bio Encased) , 100mm	l.m.	55		
11.02	(1.8.2)	Watermain DI CL50 TR FLEX (V-Bio Encased) , 150mm	l.m.	45		
11.03	(1.8.2)	Watermain DI CL50 TR FLEX (V-Bio Encased) , 200mm	l.m.	40		
11.04	(1.8.2)	Watermain DI CL50 TR FLEX (V-Bio Encased) , 250mm	l.m.	400		
11.05	(1.8.2)	Watermain DI CL50 TR FLEX (V-Bio Encased) , 300mm	l.m.	270		
11.06	(1.8.3)	Tee, 150x150x150mm	ea.	1		
11.07	(1.8.3)	Tee, 250x250x150mm	ea.	2		
11.08	(1.8.3)	Tee, 200x200x200mm	ea.	1		
11.09	(1.8.3)	Tee, 250x250x200mm	ea.	2		

ITEM NO.	MMCD Ref. / (Supp. Specs)	DESCRIPTION	UNIT	QTY	UNIT PRICE	EXTENDED AMOUNT
11.10	(1.8.3)	Tee, 300x300x200mm	ea.	3		
11.11	(1.8.3)	Robar Coupling, 150mm	ea.	7		
11.12	(1.8.3)	Gate Valve, 150mm	ea.	4		
11.13	(1.8.3)	Gate Valve, 200mm	ea.	7		
11.14	(1.8.3)	Gate Valve, 250mm	ea.	3		
11.15	(1.8.3)	Gate Valve, 300mm	ea.	3		
11.16	(1.8.3)	Tapping Valve, 250mm	ea.	1		
11.17	(1.8.3)	Reducer, 200 to 150mm	ea.	7		
11.18	(1.8.3)	Reducer, 300 to 100mm	ea.	1		
11.19	(1.8.3)	Reducer, 300 to 250mm	ea.	1		
11.20	(1.8.3)	Cross, 250x250x200x200mm	ea.	1		
11.21	(1.8.3)	Permanent Caps, 150mm	ea.	8		
11.22	(1.8.3)	45° Bend, 150mm	ea.	14		
11.23	(1.8.3)	45° Bend, 250mm	ea.	9		
11.24	(1.8.3)	45° Bend, 300mm	ea.	2		
11.25	(1.8.3)	Blow Off Valve, 100mm	ea.	1		
11.26	(1.8.3.1)	Abandoning of existing valves and removal of existing valve risers	ea.	14		
11.27	(1.8.4.1)	20mm Water Service Connection w/ Municipex and #10 AWG Tracer Wire as per Standard Detail COQ-W2b-2	ea.	18		
11.28	(1.8.4.1)	Supply and Install Terminal City Nelson type valve box c/w lid marked "Water"; including 150mm PVC riser, meter setter and precast concrete box as per Standard Detail COQ-W2m	ea.	18		
11.29	(1.8.4.2)	Transfer Existing Water Service Connection	ea.	6		
11.30	(1.8.15)	Hydrant Assembly (MMCD W4)	ea.	4		
11.31	(1.8.16)	Watermain Tie-In (150mm)	ea.	7		
11.32	(1.8.16)	Wet Tap Tie-In at Austin Ave	ea.	1		

Total Tendered Price (exclude GST): _____

(Transfer the amount to Form of Tender Summary Page 1)

Name of Contractor: _____